

Certificate

PZ-701413-13122022-E
to PB-701413-13122022

For the (re-) qualification of cleanrooms regarding the requirements on the air purity in cleanrooms and clean zones in accordance with DIN EN ISO 14644-1:2016 and with the european GMP guideline (attachment I).

Test location: **adapta BfaA – ETA**
Hochheid 2
4728 Hergenrath, Belgien

Date of test: 12.-13.12.2022

Test objects: Operating mode: **In operation**

	Classification according to DIN EN ISO 14644-1:2016	Degree of cleanliness according to EU-GMP-guideline -attachment I
Clean room A1	Class 7	Grade C
Clean room A2	Class 7	Grade C
Clean room B	Class 7	Grade C
Laminar flow area	Class 7	Grade C
Office	Class 7	Grade C
Corridor	Class 8	Grade D
Material lock Outgoing	Class 8	Grade D
Material lock Receiving	Class 8	Grade D
Personal air lock	Class 8	Grade D

Client: **adapta BfaA – ETA**

Date of requalification: **December 2023**

DIN EN ISO 14644-1:2016

The cleanrooms and the clean zones fulfill the requirements regarding the classification of the air cleanliness according to the particle concentration limits.

EU-GMP-guideline – attachment I

The cleanroom and the clean zones correspond to the recommended microbiological limits in accordance with the established grade.

January 23, 2023


M. Sc. Isabel Matsch
Head of laboratory