

# Certificate

PZ-701962-20122023-E

(Re-) qualification to confirm the requirements on the air purity in cleanrooms and clean zones in accordance with DIN EN ISO 14644-1:2016 and with the european GMP-guideline - attachment I.

**Test location:** **adapta BfaA – ETA**  
Hochheid 2  
4728 Hergenrath, Belgien

**Date of test:** 20.12.2023

**Operating mode:** **In operation**

Test objects	Classification according to DIN EN ISO 14644-1:2016	Degree of cleanliness according to EU-GMP-guideline - attachment I
Clean room A1	Class 7	Grade C
Clean room A2	Class 7	Grade C
Clean room B	Class 7	Grade C
Laminar Flow Area	Class 7	Grade C
Office	Class 7	Grade C
Corridor	Class 8	Grade D
Changing room	Class 8	Grade D
Material lock incoming goods	Class ---	Grade ---
Material lock outgoing goods	Class ---	Grade ---

**Client:** **adapta BfaA – ETA**  
Hochheid 2  
4728 Hergenrath, Belgien

**Date of requalification:** December 2024

## DIN EN ISO 14644-1:2016

The cleanrooms and the clean zones fulfill the requirements regarding the classification of the air cleanliness according to the particle concentration limits.

## EU-GMP-guideline – attachment I

The cleanrooms and the clean zones correspond to the recommended microbiological limits in accordance with the established grade.

Reutlingen, February 05, 2024



M. Sc. Isabel Matsch  
Head of laboratory